

## Requirements for the installation of Generator

1. Building Permit (make, model, size of generator \*copy of manufactures spec. on permitted location of generator.)
2. Plumbing permit (pressure test)
3. Electrical permit ( in addition third party inspection required )
4. Survey of property showing location of generator. ( setbacks to structure, size of generator, as well as property line and fencing)
5. Photo of side of structure to show placement of generator (must be a min. of 5 feet to windows, doors, openings, vents.

### **FEES**

Building \$ 100

Plumbing(pressure test) \$ 200

Electrical \$ 75 (in addition third party inspection required)

Any alterations, modifications, replacement or relocation of the aforementioned generator, shall require a new permit application to be filed and approved with the Building Department of the Village of Cedarhurst.

**As per LIPA Red Book 10.4.1** "Customers metering equipment must be placarded that generator is present."

Should you have any questions or concerns, please contact the Village of Cedarhurst Building Department at (516) 295-5770.

NFPA 37, Section 4.1.4, Engines Located Outdoors. Engines, and their weatherproof housings if provided, that are installed outdoors shall be located at least 5 ft. from openings in walls and at least 5 ft. from structures having combustible walls. A minimum separation shall not be required where the following conditions exist:

1. The adjacent wall of the structure has a fire resistance rating of at least 1 hour.
2. The weatherproof enclosure is constructed of noncombustible materials and it has been demonstrated that a fire within the enclosure will not ignite combustible materials outside the enclosure.